

**SINGLE LINE DIAGRAM- SAMPLE FLAT IN SECTOR-A COLONY**

**Incoming**

**existing 32A DP MCB to be replaced by 4P 32A MCB  
existing 2x6sqmm Al. wires to be replaced by 4x6sqmm armoured copper cable**

**MCB DB presently located outside the flat to be shifted inside**

