



**E-Tender for Construction of DMD Suite in NABARD, New Delhi RO, NABARD Tower, Rajendra Place, New Delhi - Pre-bid Meeting
– 04 August 2022, 15:00 hours**

E-Tender Ref No: NB.NDRO.DPSP.DMD Suite. 330 .2022-23 dated 21 July 2022

E-Tender ID: 20650

Corrigendum – Response to Pre bid queries

Sr. No.	Clause in E-Tender	Page No.	Existing Clause	Modified Clause
A	B	C	D	E
1	Scope of work (Para No. 7)	52	If the schedule of quantities prescribes a particular brand of materials or fittings, the same shall be considered while quoting the rates. The indicative / tentative list is given as below:	If the schedule of quantities prescribes a particular brand of materials or fittings, the same shall be considered <u>by the bidders</u> while quoting the rates, <u>but not restricted to provide other equivalent make/model duly approved by the NABARD, in case of those particular models or makes or both, which are not available in the prevailing market.</u> The indicative / tentative list is given as below:
2	Part – II BOQ Flooring (Para No. 8.1)	78	Engineered Wood Flooring Providing and Laying 10mm thick Engineered Wood with plank width of 185mm/135mm and Length of 1800mm / 2100mm/2400mm and top layer of oak/walnut natural veneer. Surface of top layer is pre finished with several layers of UV hardened acrylic lacquer, free from formaldehyde and solvents. Flooring planks shall be interlocked using patented	Engineered Wood Flooring Providing and Laying 15mm thick Engineered Wood with plank width of 185mm/135mm and Length of 1800mm / 2100mm/2400mm and top layer of oak, <u>edge-square, surface colour-natural.</u> Surface of top layer is pre finished with several layers of UV hardened acrylic lacquer, free from formaldehyde and solvents. Flooring planks shall be interlocked using patented



		<p>Plank Lock system in a glue-less, floating manner. Engineered Wood planks shall be a composition of 3 layers of board with directions of each layer oriented at right angle to the adjacent layer of natural stain in lacquer and non- bevelled/bevelled, in length and width as specified by the manufacturer The Base of Wooden Flooring shall have a backing of 6MM Thick high density PU Foam Sample to be approved by NABARD.</p>	<p>Plank Lock system in a glue-less, floating manner. Engineered Wood planks shall be a composition of 3 layers of board with directions of each layer oriented at right angle to the adjacent layer of natural stain in lacquer and non- bevelled/bevelled, in length and width as specified by the manufacturer. The Base of Wooden Flooring shall have a backing of 6MM Thick high density PU Foam <u>[Base cost: Rs. 3750 / Sq. mt]</u></p>
--	--	---	--