

Tender For Consultancy and Conducting of Structural Audit, Non Destructive Test of Head Office Building of NABARD, Mumbai- Clarifications to post Pre-bid meeting held on 07 December 2018

1. Granite/ Marble/ Stone cladding on columns, RCC walls should not be broken or tampered with for conducting the tests.
2. No Structural Audit tests will be carried out in the 7th floor.
3. EMD should be remitted by all the participating/ eligible agencies
4. No Running bills will be allowed
5. Tests like Core-Cutting etc where there is lot of noise pollution shall be carried out during Saturdays and Sundays.
6. Wherever false ceiling is required to be cut for undertaking the tests the same need to be re-fixed, make good the surface and painted in patch work.
7. Access ceiling area using own ladder by carefully opening the false ceiling
8. RCC Columns surface need to be accessed by carefully removing the electrical panels and re-fixing the same after the test in presence of licensed electrician.
9. Both digital and non-digital equipment are permitted for undertaking tests to provide accurate results.
10. The eligibility of consultants Empanelled with NABARD, Mumbai shall be subject to fulfilment of the requirements/ credentials mentioned in the technical bid of the tender document. Non-empanelled agencies/firms shall not be considered for bidding.
11. While removing if the material is damaged then procurement of new material to be included in the cost.
12. USPV test at many of the locations would require indirect testing which is acceptable to NABARD.
13. It is confirmed opening of switch board & testing would give only one USPV point per column.
14. Carbonation tests can be carried out on core extracted.
15. Re-instatement of tested locations using Micro-concrete / polymer to be included in the cost.
16. No Drawings are available, however Architectural drawings can be provided.



17. Group Insurance Policy can be considered instead CAR / workmen compensation Policy.
18. All tests to be carried out as per specifications mentioned in bill of quantities.
19. All other terms and conditions of this tender shall remain unchanged

