

**Supply, Installation on wall, Testing and Commissioning of Rising Mains and Bus-Trunking at
NABARD Head Office, B.K.C- 400051**

Price Bid

Sr. No.	Description of the item	Unit	Quantity	Rates	Amount
A	Removal of Existing Rising Mains and Bus Trunking and Supplying, Installation on wall, testing and Commissioning of 400 A(S.C. rating for 1 sec - 30 KA) Air insulated Copper Busriser along with Plug in point at every 500 MM & 2 x 25 x 6 mm Cu Earthing. Rising Mains made of 1.6mm thick IP 42 sheet Steel enclosures duly painted with powder coating, wall studs, fully PVC insulated 4 nos. Copper Bus Bars at a nominal current ratings in convenient sections and suitable for 415 V, 3 Phase, 4 wire, 50 Hz, A.C. Supply with extension joints, fire proof barriers, expansion joints, thrust pads including jointing and earthing as required(Rising mains conforming to IS 8623, TEC 439)				
1	Straight of Rising mains	Meter	40.00		
2	End feed unit for Rising mains with MCCB	Nos.	1.00		
3	End Cover to close Bus trunking	Nos.	1.00		
4	Vertical brackets @ 2 Nos. per floor for supporting the rising mains and Bus trunking	No.	18.00		
B	Removal of existing Rising Mains and Bus Trunking and Supplying, Installation on wall, testing and Commissioning of 125 A(S.C. rating for 1 sec - 5 KA) Air insulated Copper Busriser along with Plug in point at every 500 MM & 2 x 25 x 6 mm Cu Earthing. Rising Mains made of 1.6mm thick IP 42 sheet Steel enclosures duly painted with powder coating, wall studs, fully PVC insulated 4 nos. Copper Bus Bars at a nominal current ratings in convenient sections and suitable for 415 V, 3 Phase, 4 wire, 50 Hz, A.C. Supply with extension joints, fire proof barriers, expansion joints, thrust pads including jointing and earthing as required(Rising mains conforming to IS 8623, TEC 439)				
1	Straight of Rising mains	Meter	40.00		
2	End feed unit for Rising mains with MCCB	Nos.	1.00		
3	End Cover to close Bus trunking	Nos.	1.00		
4	Vertical brackets @ 2 Nos. per floor for supporting the rising mains and Bus trunking	Nos.	18.00		

C	Supplying, installing, testing and commissioning of TPN tap of box/Plug-in box made of 1.6mm thick sheet steel enclosure duly painted with powder coating on existing overhead Bus bar system complete with TPN disconnecter FSU and HRC fuses connections, earthing etc. as required with 4 pole MCB(4 nos. Plug-in boxes				
1	32 A	Nos.	18.00		
2	63 A	Nos.	18.00		
D	Buyback of Copper Rising mains and Bus Duct etc.			Lump sum	
	Total				
	GST @ 18%				
	Grand Total				